



国联质检
GUOLIAN ZHI JIAN



检 验 报 告

TEST REPORT

№ BFF231102307

产品名称：生活饮用水

委托单位：周至县城镇供水有限责任公司

检验类别：委托检验

西安国联质量检测技术股份有限公司

Xi'an Guo Lian Quality Detection Technology Co.,Ltd.

FWW106814951



西安国联质量检测技术股份有限公司

国联质检
GUOLIAN ZHI JIAN

Xi'an Guo Lian Quality Detection Technology Co.,Ltd.

检验报告

TEST REPORT

№BFF231102307

共 4 页 第 1 页

产 品 名 称 Name of sample	生活饮用水	商 标 Trade mark	/
规 格 型 号 Specification	/	生产日期 / 批号 Production date / Batch	/
检 验 类 别 Inspection sort	委托检验	到 样 日 期 Date received	2023年11月07日
检 验 地 点 Test site	西安市沣东新城科源三路137号康鸿 橙方科技园1号楼C单元	检 验 日 期 Date of inspecting	2023年11月07日~ 2023年11月17日
委 托 单 位 Inspection requestor	周至县城镇供水有限责任公司	样 品 数 量 Sample quantity	3L (1桶+1袋)
制 造 单 位 Manufacturer	/	样 品 基 数 Lot size	/
委 托 方 地 址 To the address	陕西省西安市周至县周城路26号	样 品 状 态 Sample condition	样品完好,符合检测要求
抽 样 地 点 Sampling site	/	委 托 方 代 表 Principal representative	齐胜学
检 验 项 目 Items of inspection	总大肠菌群 等 34 项		
检 验 依 据 Inspection standard	GB 5749-2022 《生活饮用水卫生标准》		
检 验 结 论 Test conclusion	所检项目符合GB 5749-2022标准要求,检测结果见下页。 签发日期: 2023年 11 月 17 日 Issuing Date: 2023-11-17		
备 注 Remarks	委托方送样,检测结果仅对来样负责。		

主检

何端

审核

代宇宇

批准

孙黎黎





检验报告

TEST REPORT

№BFF231102307

共 4 页 第 2 页

序号	检验项目	单位	限值	检验结果	单项评定	检验方法
1	总大肠菌群	MPN/100mL	不应检出	未检出 (<2)	合格	GB/T 5750.12-2023 (5.1)
2	大肠埃希氏菌	MPN/100mL	不应检出	未检出 (<2)	合格	GB/T 5750.12-2023 (7.1)
3	菌落总数	CFU/mL	100	未检出	合格	GB/T 5750.12-2023 (4.1)
4	砷	mg/L	0.01	0.000738	合格	GB/T 5750.6-2023 (9.4)
5	镉	mg/L	0.005	<0.00006	合格	GB/T 5750.6-2023 (12.4)
6	铬(六价)	mg/L	0.05	<0.004	合格	GB/T 5750.6-2023 (13.1)
7	铅	mg/L	0.01	<0.00007	合格	GB/T 5750.6-2023 (14.3)
8	汞	mg/L	0.001	<0.0001	合格	GB/T 5750.6-2023 (11.1)
9	氰化物	mg/L	0.05	<0.002	合格	GB/T 5750.5-2023 (7.1)
10	氟化物	mg/L	1.0	<0.1	合格	GB/T 5750.5-2023 (6.2)
11	硝酸盐(以N计)	mg/L	10	0.95	合格	GB/T 5750.5-2023 (8.3)
12	**三氯甲烷	mg/L	0.06	<0.000032	合格	GB/T 5750.10-2023 (4.3)
13	**一氯二溴甲烷	mg/L	0.1	<0.000016	合格	GB/T 5750.10-2023 (7.2)
14	**二氯一溴甲烷*	mg/L	0.06	<0.000015	合格	GB/T 5750.10-2023 (6.2)
15	**三溴甲烷	mg/L	0.1	<0.000041	合格	GB/T 5750.10-2023 (5.2)



检验报告

TEST REPORT

№BFF231102307

共 4 页 第 3 页

序号	检验项目	单位	限值	检验结果	单项评定	检验方法
16	**三卤甲烷 (三氯甲烷、 一氯二溴甲烷、 二氯一溴甲烷、 三溴甲烷的总 和)	/	该类化合物中 各种化合物的 实测浓度与其 各自限值的比 值之和不超过 1	<0.0014	合格	GB/T 5750.10-2023
17	二氯乙酸	mg/L	0.05	<0.002	合格	GB/T 5750.10-2023 (15.1)
18	三氯乙酸	mg/L	0.1	<0.001	合格	GB/T 5750.10-2023 (16.1)
19	色度(铂钴色 度单位)	度	15	<5	合格	GB/T 5750.4-2023 (4.1)
20	浑浊度(散射 浑浊单位)	NTU	1	<1	合格	GB/T 5750.4-2023 (5.2)
21	臭和味	/	无异臭、异味	无异臭、异 味	合格	GB/T 5750.4-2023 (6.1)
22	肉眼可见物	/	无	无	合格	GB/T 5750.4-2023 (7.1)
23	pH	/	不小于6.5且 不大于8.5	7.67	合格	GB/T 5750.4-2023 (8.1)
24	铝	mg/L	0.2	0.196	合格	GB/T 5750.6-2023 (4.5)
25	铁	mg/L	0.3	0.0516	合格	GB/T 5750.6-2023 (5.4)
26	锰	mg/L	0.1	0.00109	合格	GB/T 5750.6-2023 (6.6)
27	铜	mg/L	1.0	<0.00009	合格	GB/T 5750.6-2023 (7.6)
28	锌	mg/L	1.0	<0.0009	合格	GB/T 5750.6-2023 (8.4)
29	氯化物	mg/L	250	7.04	合格	GB/T 5750.5-2023 (5.2)



西安国联质量检测技术股份有限公司 国联质检

Xi'an Guo Lian Quality Detection Technology Co.,Ltd.

检验报告

TEST REPORT

N₀BFF231102307

共 4 页 第 4 页

序号	检验项目	单位	限值	检验结果	单项评定	检验方法
30	硫酸盐	mg/L	250	11.3	合格	GB/T 5750.5-2023 (4.2)
31	溶解性总固体	mg/L	1000	77	合格	GB/T 5750.4-2023 (11.1)
32	总硬度 (以 CaCO ₃ 计)	mg/L	450	70.4	合格	GB/T 5750.4-2023 (10.1)
33	高锰酸盐指数 (以O ₂ 计)	mg/L	3	2.88	合格	GB/T 5750.7-2023 (4.1)
34	氨 (以N计)	mg/L	0.5	0.09	合格	GB/T 5750.5-2023 (11.1)
以下空白						

注 意 事 项

NOTICE

- 1、纸质报告无“检验检测专用章”、“骑缝章”无效；

The paper report is invalid with no Detection Seal and Paging Seal.

- 2、电子报告无“检验检测专用章”无效，加密校验错误无效。

The electronic report is invalid with no Detection Seal and with decryption failed.

- 3、未经本机构同意，不得复制（全部复制除外）报告的声明。

The declaration of the report shall not be reproduced (except in full) without the consent of the Agency.

- 4、报告无授权签字人批准签字或其等效标识无效。

The report copy is invalid with no signature of approver or equivalent identification.

- 5、报告涂改无效。

The report copy is invalid if altered.

- 6、**项目为分包机构提供数据，暂未纳入本机构资质认定/能力认可的检测能力范围内，且不在本机构授权签字人授权能力范围之内。分包机构名称：青岛博拉沃检测技术有限公司，资质证书编号：191503340538。

** project provides data for alliance institutions, which is not included in the scope of mandatory approval/accreditation for the competence by our institution, and the subcontracted project is beyond the competence of the authorized signatory by our institution. Name of alliance organization: 青岛博拉沃检测技术有限公司. Qualification Certificate Number: 191503340538.

- 7、对报告若有异议，应于收到本报告之日十五日内向本单位提出，逾期不予受理。

Any objection for the report shall be informed to us within 15 days after received the report.

- 8、未经同意，不得擅自使用本报告进行不当宣传。

Without permission, it is forbidden by using this report for improper publicity.

联系地址（Address）：陕西省西咸新区沣东新城协同创新港8号楼

Building No.8, Synergetic Innovation Hub, Fengdong New City of Xixian New Area, Shaanxi Province

服务热线（Tel）：029-84346232

邮编（Zip Code）：710086

E-mail: xaunqd@126.com

http://www.xaunqd.com

客服微信号

